



**United Technologies
Research Center**

Optimization-based Management of Energy Systems

Authors: Yiqing Lin, Stella M Oggianu, Suman Dwari, Luis Arnedo

Presented by: Stella Maris Oggianu, PhD
May 11, 2010

for

**ENVIRONMENT, ENERGY SECURITY & SUSTAINABILITY
SYMPOSIUM & EXHIBITION E2S2**

Funded by:



Report Documentation Page				Form Approved OMB No. 0704-0188	
Public reporting burden for the collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to a penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.					
1. REPORT DATE MAY 2011		2. REPORT TYPE		3. DATES COVERED 00-00-2011 to 00-00-2011	
4. TITLE AND SUBTITLE Optimization-based Management of Energy Systems				5a. CONTRACT NUMBER	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S)				5d. PROJECT NUMBER	
				5e. TASK NUMBER	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) United Technologies Research Center,411 Silver Lane,East Hartford,CT,06108				8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S)	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)	
12. DISTRIBUTION/AVAILABILITY STATEMENT Approved for public release; distribution unlimited					
13. SUPPLEMENTARY NOTES Presented at the NDIA Environment, Energy Security & Sustainability (E2S2) Symposium & Exhibition held 9-12 May 2011 in New Orleans, LA. U.S. Government or Federal Rights License					
14. ABSTRACT					
15. SUBJECT TERMS					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT Same as Report (SAR)	18. NUMBER OF PAGES 12	19a. NAME OF RESPONSIBLE PERSON
a. REPORT unclassified	b. ABSTRACT unclassified	c. THIS PAGE unclassified			

Why Distributed Power Systems / Energy Microgrids?


Security of supply, reduced energy, and minimized environmental impact

Security of energy supply

- **Vulnerable loads** served under all operating conditions.
- 'Customizable' **power quality and reliability**
- **Seamless transition** between islanding and off-grid operation

Reduced energy costs and environmental impact

- Improved power systems architectures
 - **Waste heat utilization**
 - 85-90% fuel utilization vs. 40-50% for central power
 - **Renewable sources with energy storage**
 - **Maximize ROI**
 - Integrated demand/supply management:
 - **Reduced energy consumption/cost,**
 - **Peak shaving**
 - **Decrease in T&D losses and required infrastructure**
-
- **Energy microgrids are distributed power systems with the capability to work seamless in islanding and grid-connected modes.**
 - **They include thermal and electrical systems**



Energy Microgrids and Energy Management System (EMS)

Value and benefits

Objective

- To evaluate the benefits of microgrid and optimization-based supervisory system
- To understand the impact of equipment down-time and the value of perfect weather/loads information

Challenges

- Uncertainty in data and forecasts
- Results depend on microgrid architecture, weather and prices

Test cases architectures

- Determined by minimizing initial cost with renewable usage constraints

	NC	CO	OK	NY	TX
Grid	Yes, unlimited	Yes, unlimited	Yes, unlimited	Yes, unlimited	Yes, unlimited
Solar PV (KW)	35 MW	0	0	0	20 MW
Wind turbines(kW)	65 MW	70 MW	65 MW	55 MW	50 MW
CHP (microturbines+absChiller)	5 MW microturbines	17.5 MW microturbines	35 MW microturbines	27.5 MW microturbines	12.5 MW microturbines
Diesel generators	4 MW	2 MW	8 MW	12 MW	2 MW
Batteries, Lil (kWh capacity)	1 MWh	1 MWh	1 MWh	1 MWh	1 MWh


Energy Microgrids and Energy Management System (EMS)

Value and benefits: Optimization-based EMS could provide 5-20% cost savings compared to ruled base approaches


Key Results

- ✓ Feasible microgrids architectures are able to provide 50-60% annual operating cost reduction
- ✓ Optimization-based supervisory microgrid control provides an average annual 5-20% cost reduction compared with simple rule-based control strategy

Annual Operating Cost Comparison



Operating Cost by Category (Site: NC)




Annual Cost Savings of Microgrid	NC	CO	OK	NY	TX
Scenario 2 (Grid & Renewable)	17%	13%	19%	16%	21%
Scenario 3 (Grid & Microgrid, Rule-based)	41%	49%	58%	51%	54%
Scenario 4 (Grid & Microgrid, Optimization-based)	60%	56%	64%	61%	61%
CO ₂ Reduction					
Scenario 4 (Grid & Microgrid, Optimization-based)	33%	35%	36%	35%	36%

Energy Management System for Energy Systems

Overview


- Energy Management System (EMS) performs effective coordination and dispatching of distributed energy resources
 - Functionally similar to economic dispatch & unit commitment in power systems
 - Selects combination of sources and storage to meet demand
 - Considers constraints on availability of supply and operational limitations
 - Interfaces with customers and utilities
- Conventional dispatching systems are optimization-based and use steady-state models
- Renewable intermittency and memory associated with storage require planning and forecasting
- Systematic decision-making with uncertainties in demand and availability of renewable resources



Energy Management System Framework

EMS performs effective *coordination* and *dispatching* of distributed energy resources


- Renewable intermittency and memory associated with storage → planning & forecasting
- Combines elements of forecasting, model prediction, and state estimation
- Repeated solution of finite-horizon stochastic programming problems



Energy Management System Framework

Real-time Model Predictive Methodology

Repeated decision-making over finite horizons



Energy Management Framework: *Dealing with Uncertainties*

Handling Uncertainties in Predicting Energy Resources and Load Profiles

- Operational decisions have to be made in the face renewable resources and load forecast uncertainty.



- We explored different methods to determine set-points for optimal operation

Method 1, Perfect information: Use perfect/exact forecast

Method 2, expected-value solution: Use the average of different forecasted scenarios



Method 3, stochastic solution: Factors uncertainties for decision-making using a stochastic programming formulation. It assumes that:

- It is impossible to find a solution that is ideal under all circumstances
- Decisions are balanced, or hedged against the various scenarios



Energy Management Framework: *Dealing with Uncertainties*

System used to exploit Methods of Dealing with Uncertainties



- Grid-connected system
- Realistic cost data; objective to minimize monthly operating cost
- Load forecast is exact (can be easily relaxed)
- 24 hr horizon with 15 minute time-step

Energy Management Framework: *Dealing with Uncertainties*



Test Cases used to exploit Methods of Dealing with Uncertainties

Solar Radiation Forecast:

- Three cases (and predictive mean) considered
- Error in solar radiation forecast translates to error in PV power

Loads Forecast

- Two cases to capture effect of sizing and component interaction
 - Load 1: Load comparable to onsite generation capability
 - Stronger interaction between microgrid components
 - “Good” sizing of micro-grid towards grid independence
 - Load 2: Load larger than onsite generation
 - Weak interaction between microgrid components
 - Grid dependence



Energy Microgrid Framework Test Cases : Results

Exploring Methods of Dealing with Uncertainties

- Maximum cost of perfect information = Expected value of perfect information
 - Average cost difference between Method 3 and Method 1

Load 1 (Loads comparable with onsite power generation capacity)

	Method 1 Perfect Information	Method 2 Use Predictive mean	% Deviation Method 1 & Method 2	Method 3 Stochastic Programming	% Deviation Method 1 & Method 3
Case 1	\$6,404	\$6,534	2.0	\$6,694	4.5
Case 2	\$8,331	\$9,246	11.0	\$8,344	0.2
Case 3	\$7,429	\$7,908	6.4	\$7,560	1.8

Avg: 6.46%

Avg: 2.16%

Load 2 (Loads larger with onsite power generation capacity)

	Method 1 Perfect Information	Method 2 Use Predictive mean	% Deviation Method 1 & Method 2	Method 3 Stochastic Programming	% Deviation Method 1 & Method 3
Case 1	\$14,020	\$14,152	0.9	\$14,157	1.0
Case 2	\$17,996	\$18,121	0.7	\$18,082	0.5
Case 3	\$16,161	\$16,683	3.2	\$16,489	2.0

Avg: 1.6%

Avg: 1.6%

Energy Management Framework: Conclusions

Future Work and Implementation

Conclusions:

- Stochastic programming helps with decision making under uncertainty
- Stochastic programming tools can drastically reduce the value of perfect information
- Sizing, architecture and magnitude of loads dictate the required accuracy of forecasts

Future work:

- Include equipment reliability in the models / problem formulation
- Extension to include thermal power
- Extension to include load management (combined supply / demand)

The Energy Management Framework introduced in this presentation will be implemented in two energy microgrids demonstrations being prepared for DoD-ESTCP and DoE funded programs